

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation), this certificate applies to the construction product(s).

Product(s): Building hardware – Panic exit device(s) operated by a horizontal bar (refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: LAIDLAW GULF LLC
301 Mayfair Building, Dubai Investment Park Phase 1 Dubai, U.A.E.

and produced in the manufacturing plant(s): SG-15396

Intended use: For doors on escape routes.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 1125:2008

Under System 1 for the performances set out in this certificate are applied and that the performance of the construction product fulfils all the prescribed requirements for these performances.

This certificate **replaces 0359-CPR-000516-01** first issued on **2016-10-18** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

The issued document and statement(s) herein makes reference only to a presumption of conformity in accordance with the CPR Regulations EU 305/2011 (as amended). However, it is the manufacturer's or their authorised representative's sole responsibility to affix the CE logo and, by doing so, confirms full compliance and conformity to all other European mandatory directives and regulations that may also apply.

CE
0905

Signature:


95181

Date: 2020-07-23

Issue: 01

Name:

Dipl.-Ing. Bernhard Miedtank

Position: Certification Manager



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

APPENDIX TO: Certificate of Constancy of Performance

Brand: --
 Model Ref: LG.LAPH301P, LG.LAPH301S, LG.LAPH302P, LG.LAPH302S, LG.LAPH306P, LG.LAPH306S, LG.LAPH307P and LG.LAPH307S
 LG.LAPH008, LG.LAPH 009, LG.LAPH009K

Table A1. Model number details for Panic Exit Device from LAIDLAW GULF LLC

Model list	Single door	Double door		Lock & Latch type	Material (Touch Bar)
		Active door	Inactive door		
LG.LAPH301P	✓	✓	--	Rim Latch	Carbon steel
LG.LAPH301S	✓	✓	--	Rim Latch	Stainless steel
LG.LAPH306P	--	--	✓	Vertical Bolt	Carbon steel
LG.LAPH306S	--	--	✓	Vertical Bolt	Stainless steel
LG.LAPH302P	✓	✓	--	Rim Latch	Carbon steel
LG.LAPH302S	✓	✓	--	Rim Latch	Stainless steel
LG.LAPH307P	--	--	✓	Vertical Bolt	Carbon steel
LG.LAPH307S	--	--	✓	Vertical Bolt	Stainless steel
Accessories					
LG.LAPH008	Lever Outside access device				
LG.LAPH009K	Knob Outside access device				
LG.LAPH009	Lever Outside access device				
Notes:					
1. Products tested for use on timber composite doors and timber frames, as described in fire resistance test reports (see summary Table A.3)					
2. Product code P – designation represents mild steel cover					
3. Product code S – designation represents stainless steel cover					

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

APPENDIX TO: Certificate of Constancy of Performance

Table A2. Mechanical test reports and product Classification for Panic Exit Device from LAIDLAW GULF LLC ^{a, b}

Mechanical test reports	Model list	Product Classification									
		3	7	6	B ^b	1	4	2	2	B	A
160526178GZU-001	LG.LAPH301P	3	7	6	B ^b	1	4	2	2	B	A
	LG.LAPH301S	3	7	6	B ^b	1	4	2	2	B	A
	LG.LAPH306P	3	7	6	B ^b	1	4	2	2	B	C
	LG.LAPH306S	3	7	6	B ^b	1	4	2	2	B	C
160526178GZU-002	LG.LAPH302P	3	7	6	B ^b	1	4	2	2	B	A
	LG.LAPH302S	3	7	6	B ^b	1	4	2	2	B	A
	LG.LAPH307P	3	7	6	B ^b	1	4	2	2	B	C
	LG.LAPH307S	3	7	6	B ^b	1	4	2	2	B	C

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

APPENDIX TO: Certificate of Constancy of Performance

Table A3. Fire test reports for Panic Exit Device from LAIDLAW GULF LLC ^{a, b}

Fire Test Reports	Model list	Test Method	Fire Resistance (minutes)	
			Integrity (E)	Insulation (I)
171019004SHF-BP-1	LG.LAPH302P	EN 1634-1:2014	60	60
Test configuration: Single leaf single action swing timber composite fire door assembly Orientation: Open into the furnace. Model numbers assessed as having same performance: LG.LAPH302S, LG.LAPH301P, LG.LAPH301S				
171019004SHF-BP-2	LG.LAPH307P	EN 1634-1:2014	60	60
Test configuration: Single leaf single action swing timber composite fire door assembly Orientation: Open into the furnace Model numbers assessed as having same performance: LG.LAPH307S, LG.LAPH306P, LG.LAPH306S				
AU10114031-3	LG.LAPH302P	EN 1634-1:2014	62	62
Test configuration: Single leaf single action swing timber fire composite door assembly Orientation: Open away from the furnace Model numbers assessed as having same performance: LG.LAPH302S, LG.LAPH301P, LG.LAPH301S				
AU10114031-4	LG.LAPH307P	EN 1634-1:2014	90	90
Test configuration: Single leaf single action swing timber composite fire door assembly Orientation: Open away from the furnace Model numbers assessed as having same performance: LG.LAPH307S, LG.LAPH306P, LG.LAPH306S				
AU10114031-5	LG.LAPH302P (active) LG.LAPH307P (inactive)	EN 1634-1:2014	70	70
Test configuration: Double leaves single action swing timber composite fire door assembly Orientation: Open into the furnace Model numbers as double doors assessed as having same performance: (LG.LAPH302S, LG.LAPH307S), (LG.LAPH301P, LG.LAPH306P), (LG.LAPH301S, LG.LAPH306S)				
AU10114031-6	LG.LAPH302P (active) LG.LAPH307P (inactive)	EN 1634-1:2014	70	70
Test configuration: Double leaves single action swing timber composite fire door assembly Orientation: Open away from the furnace Model numbers as double doors assessed as having same performance: (LG.LAPH302S, LG.LAPH307S), (LG.LAPH301P, LG.LAPH306P), (LG.LAPH301S, LG.LAPH306S)				

Notes

- The panic exit device(s) are to be installed in accordance with the installation instructions for the product(s).
- Digit 4 grade "B" was based on the test result from fire resistance test(s) (Refer to Table A3).

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

APPENDIX TO: Certificate of Constancy of Performance

Table A4. Panic Exit Device - EN 1125 Table ZA.1 Clauses for Panic Exit Device from LAIDLAW GULF LLC

Product:	Panic exit devices operated by a horizontal bar as covered by the scope of EN1125.	
Intended uses:	For doors on escape routes.	
Requirement / characteristic	Requirement clauses in this European Standard	Results
Ability to release (for doors on escape routes)	4.1.2 Release function	< 1 second
	4.1.3 Panic exit device mounting	Surface mounted on inner face of door leaf.
	4.1.5 Exposed edges and corners	No sharp edges
	4.1.7 Double doorset	Pass
	4.1.9 Bar installation	Z < 150 mm
	4.1.10 Bar length	X/Y > 60%
	4.1.11 Bar projection	Standard projection Category 2: W < 100 mm
	4.1.12 Bar end	The operating bar does not protrude beyond either of the end support brackets
	4.1.13 Operating bar face	Type A, V > 18 mm
	4.1.14 Test rod	The device does not trap the test rod in any position of the operating bar
	4.1.15 Door face gap	R > 25 mm
	4.1.16 Accessible gap	The test piece placed in any accessible gap cannot prevent the correct operation of the device
	4.1.17 Door free movement	The device does not include any element impeding the free movement of the door once it is released
	4.1.18 Top vertical bolt	Pass (LG.LAPH306P, LG.LAPH306S, LG.LAPH307P, LG.LAPH307S only)
	4.1.20 Keepers	The keeper protects the door frame from the damage caused by the door closing and opening
	4.1.21 Keepers dimensions	Pass (LG.LAPH306P, LG.LAPH306S, LG.LAPH307P, LG.LAPH307S only)
	4.1.23 Door mass and dimensions	Mass 200 Kg, height ≤ 2500 mm, width 650 to 1166 mm (for CMP301P/S and CMP306P/S), width 650mm to 1320mm (for CMP302P/S and CMP307P/S) (dimensions mechanical only)
4.1.24 Outside access device	Pass	
4..2.2 Release forces	< 80 N with the door unloaded < 220 N with the door loaded with 1 000 N	
4.2.7 Security requirement	Grade 2: the device remains locked when a force of 1 000 N is applied to the door	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000516-01

APPENDIX TO: Certificate of Constancy of Performance

Durability of ability to release against aging and degradation (for doors on escape routes)	4.1.4; 4.2.9 Corrosion resistance	Grade 4: Very high resistance (240 hours)
	4.1.6 Temperature range	-10°C; +60°C
	4.1.19 4.2.6 Covers for vertical rods	NPD – No performance Determined
	4.1.22 Lubrication	Refer to Manufacturer's Maintenance Instructions
	4.2.3 Re-engagement force	< 50 N
	4.2.4 Durability	Grade 7: 200 000 test cycles
	4.2.5 Abuse resistance - Horizontal bar	Pass
	4.2.6 Abuse resistance - Vertical rod	Pass (LG.LAPH306P, LG.LAPH306S, LG.LAPH307P, LG.LAPH307S only)
4.2.8; 4.2.2; 4.1.17 Final examination	The device is released with a force < 80 N, with the door unloaded, and < 220 N, with the door loaded with 1 000 N, and the door moves freely	
Self closing ability C (for fire/smoke doors on escape routes)	4.2.3 Re-engagement force	< 50 N
Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes)	4.2.4 Durability	Grade 7: 200 000 test cycles
	4.2.3 Re-engagement force	< 50 N
Resistance to fire E (integrity) and (insulation) (for fire doors on escape routes)	4.1.8; Annex B Suitability of panic exit devices for use on fire/smoke resisting door assemblies	Grade B: suitable for use on fire/smoke resisting door assemblies (refer to Table A3).
Control of Dangerous substances	4.1.25 Dangerous substances	No dangerous substances declared for this product/intended use

END OF DOCUMENT