



CERTIFICATE OF APPROVAL

No CF 5762

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

INTERNATIONAL INTERIOR SOLUTIONS LTD

PO Box 254, Wirral CH29 9FH, United Kingdom
TEL: +44 (0) 771 0030991

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT
LGAI Stainless Steel Hinges

TECHNICAL SCHEDULE
TS24 The Contribution of
Single Axis Hinges to the Fire
Resistance of Door Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued:
Valid to:

11th September 2019
6th June 2023



CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

1. This approval relates to the use of the following specific LGAI stainless steel ball bearing, single axis hinges:

LG.LA Reference		Alternative Reference		Size	Description	Grade
Squared Corners	Radiused Corners	Squared Corners	Radiused Corners			
LG.LA150.076	LG.LA150.076R	37 150.2	37 150.1	76 x 50 x 2 mm*	Ball Bearing	7
LG.LA150W.076	LG.LA150W.076R	37 150W.2	37 150W.1	76 x 50 x 2 mm*	Washed	7
LG.LA160W.102	LG.LA160W.102R	37 160W.2	37 160W.1	102 x 76 x 2 mm*	Washed	7
LG.LA160C.102	LG.LA160C.102R	37 900.2	37 900.1	102 x 76 x 3 mm	3 knuckle concealed bearing	13
LG.LA160.102B	LG.LA160.102BR	37 700.2	37 700.1	102 x 76 x 2.5 mm	Ball Bearing	13
LG.LA160S.102	LG.LA160S.102R	37 810.2	37 810.1	102 x 76 x 3 mm	Ball Bearing security hinge	13
LG.LA160H.102	LG.LA160H.102R	37 800.2AL	37 800.1AL	102 x 76 x 3 mm	Ball Bearing with hospital tip	13
LG.LA160.102	LG.LA162.102	37 800.2	37 800.1	102 x 76 x 3 mm	Ball Bearing	13
LG.LA166.102	LG.LA166.102R	37 802.2	37 802.1	102 x 89 x 3 mm	Ball Bearing	13
LG.LA161.102	LG.LA163.102	37 801.2	37 801.1	102 x 102 x 3 mm	Ball Bearing	13
LG.LA167.114	LG.LA167.114R	37 806.2	37 806.1	114 x 102 x 3 mm	Ball Bearing	13
LG.LA167.114B	LG.LA167.114BR	37 816.2	37 816.1	114 x 114 x 3 mm**	Ball Bearing	13
LG.LA168.114	LG.LA168.114R	37 807.2	37 807.1	114 x 102 x 3.5 mm**	Ball Bearing	13
LG.LA168.114B	LG.LA168.114BR	37 817.2	37 817.1	114 x 114 x 3.5 mm**	Ball Bearing	13
LG.LA178.127	LG.LA178.127R	37 808.2	37 808.1	127 x 76 x 3 mm	Ball Bearing	13
LG.LA178.089	LG.LA178.089R	37 818.2	37 818.1	127 x 89 x 3 mm	Ball Bearing	13
LG.LA178.102	LG.LA178.102R	37 828.2	37 828.1	127 x 102 x 3 mm	Ball Bearing	13

* Grade 7 hinges are not approved for use with steel-based doorsets, or 90 & 120 minute timber/mineral based doorsets.

** Not approved for use with 44 mm thick 30 minute timber/mineral-based doorsets.

2. Hinges are available with square and radiused corners, and Grade SS201, SS304 and SS316 stainless steel



CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

3. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT) – see product table on page 2 for exceptions.

Latched and unlatched, door assemblies consisting of uninsulated or insulated metal door assemblies in metal frames with or without intumescent seals having a fire resistance up to 240 minutes (Code IMM/MM) – see product table on page 2 for exceptions.

4. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
5. This approval relates to the use of the above single axis hinges in contributing to the fire resistance performance of timber based doorsets and metallic based doorsets, as defined in BS EN 1634-1 or BS 476: Part 22: 1987.
6. The hinges are approved on the basis of:
- i) Initial type testing to EN1935 and EN 1634-1
 - ii) An appraisal against TS24
 - iii) Certification of quality management system to ISO 9001: 2008.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with TS24 requirements
7. The door assembly shall be a CERTIFIRE approved product or have achieved the appropriate fire resistance performance when tested at a UKAS accredited laboratory in accordance with BS 476: Part 22: 1987 and/or BS EN 1634:1.
8. The hinges should only be used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987), the critical aspects of the doorset construction are considered to be the material of the door frame, the leaf to frame clearance gaps and the lipping material. Attention should be paid to these details and these should not be amended from that previously fire tested. Where this information is not known the following minimum specification will be followed:

CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

- a. 30 and 60 minute timber and mineral-based assemblies (ITT):
 - i) Door frame density - 460 kg/m³ (30 minutes), 640 kg/m³ (60 minutes)
 - ii) Door leaves shall have a minimum thickness of 44 mm for 30 minute applications and 54 mm for 60 minute applications.
 - iii) Lipping density - 640 kg/m³.
 - iv) Leaf to frame clearance gaps not to exceed 3 mm maximum
 - b. Steel-based assemblies (MM/IMM)
 - i) Door leaves shall have a minimum thickness of 44 mm for up to 240 minute applications.
9. For 90 minute and 120 minute timber and mineral-based assemblies (ITT), LGAI hinges shall only be fitted to doorsets which have previously been tested with hinges of a similar size, subject to the following requirements:
- i) The required intumescent protection shall be as tested by the chosen door manufacturer. In all cases this shall be a minimum of a 2 mm thick 'Interdens' or graphite based intumescent sheet material incorporated beneath each hinge blade, however, this protection shall be increased as required based on the chosen doorset manufacturers test data.
 - ii) A minimum of 10 mm of perimeter intumescent fire seal shall by-passed the hinges. Where the perimeter intumescent fire seal on the original test of the chosen doorset by-passes the hinge by more than 10 mm, this shall be maintained on the doorset incorporating the LGAI chosen hinges.
 - iii) The critical dimensions of the LGAI hinge to be used shall be based on the size of the hinge tested originally by the chosen doorset manufacturer, with the following tolerance:

CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

Hinge specification of chosen doorset	
Component/dimension	Tolerance/Rule
Hinge blade	
Width	+0/-5% of tested hinge
Height	+/-10% of tested hinge
Thickness	+/-15% of tested hinge
Knuckle	
Diameter	Minimum 11 mm
Fixings	
Quantity	Maximum 4No. fixings tested
Size	4.8 mm dia. Minimum
Length	No shorter than that tested
Position (width)	+/-10% from the positions of the fixings in the tested hinge when measured with respect to the centre lines of the blade

Note: Where the LGAI hinge does not comply with the parameters identified above it shall not be used in conjunction with the chosen 90 minute and 120 minute timber and mineral-based assemblies (ITT).

10. When fitted to insulated timber or mineral composite door assemblies, the required additional intumescent protection will be as follows:
- i) The required protection for 30 minute ITT applications will be 1 mm thickness of mono ammonium phosphate or graphite-based intumescent sheet material behind both blades.
 - ii) The required protection for 60 minute ITT applications will be 2 mm thickness of mono ammonium phosphate or graphite-based intumescent sheet material behind both blades.
 - iii) The required intumescent protection for 90 and 120 minute ITT applications shall be as tested by the chosen door manufacturer. In all cases this shall be a minimum of a 2 mm thick 'Interdens' or graphite based intumescent sheet material incorporated beneath each hinge blade, however, this protection shall be increased as required based on the chosen doorset manufacturers test data.



CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

- iv) In addition for 90 and 120 minute ITT applications, a minimum of 10 mm of perimeter intumescent fire seal shall by-passed the hinges. Where the perimeter intumescent fire seal on the original test of the chosen doorset by-passes the hinge by more than 10 mm, this shall be maintained on the doorset incorporating the LGAI chosen hinges.

Failure to install the protection will invalidate this certificate

11. The hinges may only be fitted in the manner described in this certificate and subject to any limitations on the inclusion of hinges specified for the door leaf. This approval is applicable only to the specified hinges used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and when using appropriate intumescent protection.
12. Hinges shall only be fitted using the fixings supplied by the hinge manufacturer. Regard should be paid to the maximum door mass permitted to be used with the hinge (see classifications).
13. The ITT doorsets shall be installed in accordance with BS 8214.
14. The approval relates to ongoing production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 5762 INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

15. The following table show acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓#	✓#	✓*	✗	✗
FD30	✓#	✓#	✓*	✗	✗
FD60	✓#	✓#	✓	✗	✗
FD90	✓#	✓#	✓#	✗	✗
FD120	✓#	✓#	✓#	✗	✗
FD240	✓#	✓#	✗	✗	✗
E 20	✓#	✓#	✓*	✗	✗
EI 20	✓#	✓#	✓*	✗	✗
E 30	✓#	✓#	✓*	✗	✗
EI 30	✓#	✓#	✓*	✗	✗
E 60	✓#	✓#	✓	✗	✗
EI 60	✓#	✓#	✓	✗	✗
E 90	✓#	✓#	✓#	✗	✗
EI 90	✓#	✓#	✓#	✗	✗
E 120	✓#	✓#	✓#	✗	✗
EI 120	✓#	✓#	✓#	✗	✗
E 240	✓#	✓#	✗	✗	✗
EI 240	✓#	✓#	✗	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved
- ✓* - Excludes LG.LA167.114B, LG.LA167.114BR, 37 816.2, 37 816.1, LG.LA168.114, LG.LA168.114R, 37 807.2, 37 807.1, LG.LA168.114B, LG.LA168.114BR, 37 817.2 and 37 817.1 hinges from 20 and 30 minute ITT doorsets
- ✓# - Excludes all Grade 7 hinges





CERTIFICATE No CF 5762

INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAI Stainless Steel Hinges

16. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Classification codes

The approval provides the following classifications:

All Grade 13 hinges except LG.LA160S.102, LG.LA160S.102 R, 37 810.2 and 37 810.1:

4	7	6	1	1	4	0	13
---	---	---	---	---	---	---	----

LG.LA160S.102, LG.LA160S.102 R, 37 810.2 and 37 810.1hinges:

4	7	6	1	1	4	1	13
---	---	---	---	---	---	---	----

All grade 7 hinges:

2	7	2	1	1	4	0	7
---	---	---	---	---	---	---	---

Page 8 of 9 Signed
J/053

Issued: 11th September 2019
Valid to: 6th June 2023



CERTIFICATE No CF 5762
INTERNATIONAL INTERIOR SOLUTIONS LTD

LGAJ Stainless Steel Hinges

Further Information

Further information regarding the details contained in this certificate may be obtained from International Interior Solutions Ltd (Tel: +44 (0) 771 0030991).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 9 of 9 Signed
J/053

Issued: 11th September 2019
Valid to: 6th June 2023